

HMRZ.EX26905 - Gate Valves

Gate Valves

[See General Information for Gate Valves](#)**NEWAGE FIRE PROTECTION INDUSTRIES PVT LTD**4, Champaklal Udyong Bhavan, Sion E
Mumbai, Maharashtra 400022 INDIA

EX26905

Pattern	Model	Size, in.	End Configuration	Rated Pressure, psig
NRS	NP-NRSH-300 F	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	300
NRS	NP-NRSH-250 F	2.5, 3, 4, 5, 6, 8, 10, 12, 14, 16, 18, 20, 24	F by F (ANSI Flange)	250
NRS	NP-NRSH-200 F	2.5, 3, 4, 5, 6, 8, 10, 12, 14, 16, 18, 20, 24	F by F (ANSI Flange)	200
NRS	NP-NRSH-PN16-300 F	2.5, 3, 4, 5, 6, 8	F by F (BS Flange)	300
NRS	NP-NRSH-PN16-250 F	10, 12	F by F (BS Flange)	250
NRS	NP-NRSH-PN16-200 F	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (BS Flange)	200
NRS	NP-NRSH-300 G	2.5, 3, 4, 5, 6, 8, 10, 12	G by G	300
NRS	NP-NRSH-250 G	2.5, 3, 4, 5, 6, 8, 10, 12	G by G	250
NRS	NP-NRSH-200 G	2.5, 3, 4, 5, 6, 8, 10, 12	G by G	200
NRS	NP-NRSH-PN16-300 G	2.5, 3, 4, 5, 6, 8	G by G	300
NRS	NP-NRSH-PN16-250 G	10, 12	G by G	250
NRS	NP-NRSH-PN16-200 G	2.5, 3, 4, 5, 6, 8, 10, 12	G by G	200
OS&Y	NP-OSY-300 F	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	300
OS&Y	NP-OSY-250 F	2, 2.5, 3, 4, 5, 6, 8, 10, 12, 14, 16, 18, 20, 24	F by F (ANSI Flange)	250
OS&Y	NP-OSY-200 F	2, 2.5, 3, 4, 5, 6, 8, 10, 12, 14, 16, 18, 20, 24	F by F (ANSI Flange)	200
OS&Y	NP-OSY-300 G	2, 2.5, 3, 4, 5, 6, 8, 10, 12	G by G	300
OS&Y	NP-OSY-250 G	2, 2.5, 3, 4, 5, 6, 8, 10, 12	G by G	250
OS&Y	NP-OSY-200 G	2, 2.5, 3, 4, 5, 6, 8, 10, 12	G by G	200
OS&Y	NP-OSY-232 G	2, 2.5, 3, 4, 5, 6, 8, 10, 12	G by G	232
OS&Y	NP-OSY-PN16 -300 F	2, 2.5, 3, 4, 5, 6, 8	F by F (BS Flange)	300
OS&Y	NP-OSY-PN16-250 F	10, 12	F by F (BS Flange)	250
OS&Y	NP-OSY-232 F	2, 2.5, 3, 4, 5, 6, 8, 10, 12, 14, 16, 18, 20, 24	F by F (BS Flange)	232

OS&Y	NP-OSY-175 F	8, 10, 12, 14, 16, 18, 20, 24	F by F (BS Flange)	175
OS&Y	NP-OSY-PN 16 F	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F (DIN Flange)	232
OS&Y	NP-OSY-PN 10 F	8, 10, 12	F by F (DIN Flange)	175
NRS	NP-NRSPF-300 G	4, 6, 8, 10, 12	G by G	300
NRS	NP-NRSPF-250 G	4, 6, 8, 10, 12	G by G	250
NRS	NP-NRSPF-200 G	4, 6, 8, 10, 12	G by G	200
NRS	NP-GV-PN 16 F	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (DIN Flange)	232
NRS	NP-GV-PN 10 F	8, 10, 12	F by F (DIN Flange)	175
NRS	NP-GV-232 F	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (BS Flange)	232
NRS	NP-GV-175 F	8, 10, 12	F by F (BS Flange)	175
NRS	NP-NRSPF-300 F	4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	300
NRS	NP-NRSPF-250 F	4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	250
NRS	NP-NRSPF-200 F	4, 5, 6, 8, 10, 12	F by F (ANSI Flange)	200
NRS	NP-NRSPF-PN16-300 F	4, 5, 6, 8	F by F (BS Flange)	300
NRS	NP-NRSPF-PN16-250 F	10, 12	F by F (BS Flange)	250
NRS	NP-NRSPF-232 F	4, 5, 6, 8, 10, 12	F by F (BS Flange)	233
NRS	NP-NRSPF-175 F	8, 10, 12	F by F (BS Flange)	175
NRS	NP-NRSPF-PN 16 F	4, 5, 6, 8, 10, 12	F by F (DIN Flange)	233
NRS	NP-NRSPF-PN10 F	8, 10, 12	F by F (DIN Flange)	175
NRS	NP-NRSH-232 F	2.5, 3, 4, 5, 6, 8, 10, 12, 14, 16, 18, 20, 24	F by F (BS Flange)	232
NRS	NP-NRSH-175 F	8, 10, 12, 14, 16, 18, 20, 24	F by F (BS Flange)	175
NRS	NP-NRSH-PN 16 F	2.5, 3, 4, 5, 6, 8, 10, 12	F by F (DIN Flange)	232
NRS	NP-NRSH-PN 10 F	8, 10, 12	F by F (DIN Flange)	175
OS&Y	NPOSY-300F	2.5, 3, 4, 5, 6, 8, 10, 12	Flange & Flange	300
NRS	NPNRS-300F	2.5, 3, 4, 5, 6, 8, 10, 12	Flange & Flange	300
OS&Y	NPOSY-200F	2, 2.5, 3, 4, 5, 6, 8, 10, 12	Flange & Flange	200
OS&Y	NPOSY-200FG		Flange & Grooved	200
OS&Y	NPOSY-200GG		Grooved & Grooved	200
NRS	NPNRS-200F		2.5, 3, 4, 5, 6, 8, 10, 12	Flange & Flange
NRS	NPNRS-200FG	Flange & Grooved		200
NRS	NPNRS-200GG	Grooved & Grooved		200

Last Updated on 2018-06-07

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"